ДЕРЖАВНЕ ПІДПРИЄМСТВО
«СЕРТИФІКАЦІЙНИЙ ВИПРОБУВАЛЬНИЙ ЦЕНТР
ОПАЛЮВАЛЬНОГО ОБЛАДНАННЯ» (ДП «СВЦОО»)

1О024
Сертифікація продукції

СЕРТИФІКАТ ЕКСПЕРТИЗИ ТИПУ

TYPE EXAMINATION CERTIFICATE
Module B

Зареєстровано в Реєстрі ООВ ДП «СВЦОО» за № **UA.TR.012.C.0291.1-25**
Registered at the Record of conformity assessment body under №

Термін дії **Since July, 30 2025 till January, 05 2030**
Term of validity

Сертифікат видано **LIMITED LIABILITY COMPANY "PLANT "CONVECTOR",**
Certificate is issued on **code 30104493,**
88007, Uzhhorod, Granitna str., 5

Продукція **Heating gas convective appliance type AKOG**
Production **Device category - $II_{2H3B/P}$,**
Gas supply pressure - (1274+100) Pa, (1960+150) Pa, (2940+200) Pa

7321 81
Код УКТЗЕД, ДК 016/ UKT ZED code, DK 016
27.52.12
Код ДКПП/ DKPP code

Відповідає вимогам **Technical regulations for appliances running on gaseous fuel**
Comply with the requirements **(Resolution of the Cabinet of Ministers of Ukraine as 04.07.2018 № 814),**
ДСТУ EN 613:2022 (EN 613:2021, IDT),
ДСТУ EN 613:2006 (EN 613:2000, IDT)

Виробник **LIMITED LIABILITY COMPANY "PLANT "CONVECTOR",**
Producer **code 30104493,**
88007, Uzhhorod, Granitna str., 5

Місце виробництва **LIMITED LIABILITY COMPANY "PLANT "CONVECTOR",**
Place of production **code 30104493,**
88007, Uzhhorod, Granitna str., 5

Додаткова інформація **The description of models is contained in the attachments 1, 2 to the certificate**
Additional information

Сертифікат видано органом з оцінки відповідності **Conformity assessment body SE «CTCHE», Ukraine,**
Certificate is issued by the conformity assessment body **03150, Kyiv, Zagorodnya St.,15 (the legal address),**
03045, Kyiv, Plescheeva St.,10 (de facto address).
The number of the assessment body № UA.TR.012
Contact phone +38044-360-80-98, +38044-259-46-24

На підставі **Test report № 104/25 ВКОВ as 10.07.2025 TL SE «CTCHE» (accreditation certificate № 20122 as 28.09.2023), conformity assessment decision № 84-P/25 as 29.07.2025**
On the grounds of

Керівник органу з оцінки відповідності **А.П. Олефіренко**
Director of the conformity assessment body
М.П. Stamp

УКРАЇНА ДЕРЖАВНЕ ПІДПРИЄМСТВО СЕРТИФІКАЦІЙНИЙ ВИПРОБУВАЛЬНИЙ ЦЕНТР ОПАЛЮВАЛЬНОГО ОБЛАДНАННЯ
Ідентифікаційний код 14315701

Чинність сертифіката можна перевірити в базі даних органу з оцінки відповідності, що розміщена на:
Validity of the Certificate can be checked on the base of data of the conformity assessment body, which is loaded at:
www.svcoo.kiev.ua

ДЕРЖАВНЕ ПІДПРИЄМСТВО
«СЕРТИФІКАЦІЙНИЙ ВИПРОБУВАЛЬНИЙ ЦЕНТР
ОПАЛЮВАЛЬНОГО ОБЛАДНАННЯ» (ДП «СВЦОО»)

1О024
Сертифікація продукції

ДОДАТОК ДО СЕРТИФІКАТУ ЕКСПЕРТИЗИ ТИПУ

ATTACHMENT TO THE TYPE EXAMINATION CERTIFICATE
№ 1

Зареєстровано в Реєстрі ООВ ДП «СВЦОО» за № **UA.TR.012.C.0291.1-25**
Registered at the Record of conformity assessment body under №

Heating gas convective appliance:

- with the SIT valve, models:

AKOG-2M-...-SP	**rated heat output 2,3 ± 5% kW**
AKOG-2,5L-...-SP	**rated heat output 2,5 ± 5% kW**
AKOG-3-...-SP	**rated heat output 3,0 ± 5% kW**
AKOG-4-...-SP	**rated heat output 4,0 ± 5% kW**
AKOG-4L-...-SP	**rated heat output 4,0 ± 5% kW**
AKOG-5-...-SP	**rated heat output 5,0 ± 5% kW**
AKOG-100-...-SP	**rated heat output 8,5 ± 5% kW**

- with the HUK valve, models:

AKOG-2M-(H)-...-SP	**rated heat output 2,3 ± 5% kW**
AKOG-2,5L-(H)-...-SP	**rated heat output 2,5 ± 5% kW**
AKOG-3-(H)-...-SP	**rated heat output 3,0 ± 5% kW**
AKOG-4-(H)-...-SP	**rated heat output 4,0 ± 5% kW**
AKOG-4L-(H)-...-SP	**rated heat output 4,0 ± 5% kW**
AKOG-5-(H)-...-SP	**rated heat output 5,0 ± 5% kW**
AKOG-100-(H)-...-SP	**rated heat output 8,5 ± 5% kW,**

where instead of dots (...) may be letters and/or numbers that identify differences between types based on external design features and do not affect technical characteristics and safety indicators.
The devices can be completed with ventilating blocks like FU AKOG which are intended for acceleration of heat exchange (convection).
Devices convective heating gas AKOG are intended for heating of separate inhabited, public household and industrial rooms with observance of requirements of the State construction norms "Gas supply", the volume specified in the table.

	APPLIANCE TYPE						
	AKOG-2M-...-SP	AKOG-2,5Л-...-SP	AKOG-3-...-SP	AKOG-4-...-SP	AKOG-4Л-...-SP	AKOG-5-...-SP	AKOG-100-...-SP
	AKOG-2M-(H)- ...-SP	AKOG-2,5L-(H)- ...-SP	AKOG-3-(H)- ...-SP	AKOG-4-(H)- ...-SP	AKOG-4L-(H)- ...-SP	AKOG-5-(H)- ...-SP	AKOG-100-(H)- ...-SP
Volume of heated room, m^3, not more	**55**	**60**	**75**	**100**	**100**	**125**	**200**

Керівник органу з оцінки відповідності **А.П. Олефіренко**
Director of the conformity assessment body
М.П. Stamp

Ідентифікаційний код 14315701

Чинність сертифіката можна перевірити в базі даних органу з оцінки відповідності, що розміщена на:
Validity of the Certificate can be checked on the base of data of the conformity assessment body, which is loaded at:
www.svcoo.kiev.ua

ДЕРЖАВНЕ ПІДПРИЄМСТВО
«СЕРТИФІКАЦІЙНИЙ ВИПРОБУВАЛЬНИЙ ЦЕНТР
ОПАЛЮВАЛЬНОГО ОБЛАДНАННЯ» (ДП «СВЦОО»)

1О024
Сертифікація продукцій

ДОДАТОК ДО СЕРТИФІКАТУ ЕКСПЕРТИЗИ ТИПУ

ATTACHMENT TO THE TYPE EXAMINATION CERTIFICATE

№ 2

Зареєстровано в Реєстрі ООВ ДП «СВЦОО» за № **UA.TR.012.C.0291.1-25**
Registered at the Record of conformity assessment body under №

The principle of operation of the devices is heating due to gas combustion and heat transfer to the room air (convective heat exchange).
The devices are manufactured with a closed combustion chamber (heat exchanger (housing)).
According to the method of mounting - wall (mounting on the wall of the heating room).
According to the method of air supply - parapet - the air required for the combustion of natural gas and the removal of combustion products is carried out through the flue, which passes through the outer wall of the heated room.
The designation of devices includes the component "...", which may be replaced by letters and/or numbers that determine the difference between types of devices based on external design features that do not affect technical and safety indicators.
For example, devices can be supplied:
- with different design of casings;
- with different design of perforations on the casing (rectangular, diamond-shaped, round, etc.).
The type of casing or perforations on it does not affect the operation, parameters, characteristics of the device, including safety indicators, as the other components and components of the device are identical for all types.
The difference between the types of devices is in the overall dimensions, which are determined by the power of the device.
In addition, the customer may offer his designation of the component "...", in order to identify products which he supplies to the market.

APPLIANCE TYPE	TYPE OF GAS VALVE (AUTOMATIC OF SAFETY)	DESIGNATION OF DESIGN DOCUMENTATION
AKOG-2M-...-SP	630 EUROSIT, made in Italy	A2M3.030.004
AKOG-3-...-SP		A2M3.030.004-02
AKOG-4-...-SP		A2M3.030.004-01
AKOG-5-...-SP		КОНВ.632268.001
AKOG-100-...-SP		АЭКА.632268.079
AKOG-2,5L-...-SP		АЭКА.632268.010
AKOG-4L-...-SP		АЭКА.632268.010-01
AKOG-2M-(H)- ...-SP	Gas valve HUK - 0.635591.018, made by Limited Liability Company "Plant "Convector", Ukraine	АЭКА.632268.072
AKOG-3-(H)- ...-SP		АЭКА.632268.072-02
AKOG-4-(H)- ...-SP		АЭКА.632268.072-01
AKOG-5-(H)- ...-SP		АЭКА.632268.073
AKOG-100-(H)- ...-SP		АЭКА.632268.080
AKOG-2,5L-(H)- ...-SP		АЭКА.632268.077
AKOG-4L-(H)- ...-SP		АЭКА.632268.078

The devices are completed with automatic of safety 630 EUROSIT, made in Italy, or HUK (0.635591.018) made by Limited Liability Company "Plant "Convector", Ukraine.
Automatic of safety automatically maintains the set temperature of air indoors and provides:
1) automatic shut-off of gas supply to the device at:
- attenuation of the ignition burner;
- insufficient draft in the air duct;
2) ignition of the burner with a piezo igniter from the control panel;
3) setting the air temperature of the heated room and its automatic maintenance;
4) stable power, regardless of fluctuations in gas pressure in the gas supply network.

Керівник органу з оцінки відповідності **А.П. Олефіренко**
Director of the conformity assessment body
М.П./Stamp

Ідентифікаційний код 14315701

Чинність сертифіката можна перевірити в базі даних органу з оцінки відповідності, що розміщена на:
Validity of the Certificate can be checked on the base of data of the conformity assessment body, which is loaded at:
www.svcoo.kiev.ua

ДЕРЖАВНЕ ПІДПРИЄМСТВО
«СЕРТИФІКАЦІЙНИЙ ВИПРОБУВАЛЬНИЙ ЦЕНТР
ОПАЛЮВАЛЬНОГО ОБЛАДНАННЯ» (ДП «СВЦОО»)

1О024
Сертифікація продукції

СЕРТИФІКАТ

CERTIFICATE

відповідність типу на основі внутрішнього контролю виробництва з проведенням перевірок продукції під наглядом через певні інтервали часу (Модуль С2) /
based on internal production control plus supervised product checks at random intervals (Module C2)

Зареєстровано в Реєстрі ООВ ДП «СВЦОО» за № **UA.TR.012.C.0300-25**
Registered at the Record of conformity assessment body under №

Термін дії **since August, 11 2025 till August, 10 2027**
Term of validity

Сертифікат видано **LIMITED LIABILITY COMPANY "PLANT "CONVECTOR",**
Certificate is issued to **code 30104493,**
88007, Uzhhorod, Granitna str., 5

This certificate confirms that the production process (UKT ZED codes 7321 81, 8481 10, 9025 19, 8416 20, 8414 59, DK codes 27.52.12, 28.12.14, 26.51.51, 28.21.11, 28.25.20) and its monitoring ensure compliance of the manufactured devices with the type described in the type examination certificates № UA.TR.012.C.0040-20, № UA.TR.012.C.0041-20, № UA.TR.012.C.0042-20, № UA.TR.012.C.0043-20, № UA.TR.012.C.0044-20, № UA.TR.012.C.0290-25, № UA.TR.012.C.0291.1-25 in accordance with the requirements: module C2 (according to requirements Attachment 2 items 12-16 of Technical regulations for appliances running on gaseous fuel (Resolution of the Cabinet of Ministers of Ukraine as 04.07.2018 № 814)

Продукція **Heating gas convective appliance (convectors) type AKOG; Automation of regulation and safety of HUK; Thermocouples controlling trademark TOLLI; Thermocouples controlling trademark ARTI; Gas injection burners trademark ARTI type BR; Gas injection burners trademark TOLLI type PGI, ventilating blocks like FU AKOG**
Production

Виробник **LIMITED LIABILITY COMPANY "PLANT "CONVECTOR",**
Producer **code 30104493,**
88007, Uzhhorod, Granitna str., 5

Місце виробництва **LIMITED LIABILITY COMPANY "PLANT "CONVECTOR",**
Place of production **code 30104493,**
88007, Uzhhorod, Granitna str., 5

Додаткова інформація **Supervision of products in order to check the quality of internal production control with product inspections is carried out at random intervals (once a year)**
Additional information

Сертифікат видано органом з оцінки відповідності **CAB SE «CTCHE», Ukraine,**
Certificate is issued by the conformity assessment body **03150, Kyiv, Zagorodnya St.,15 (the legal address),**
03045, Kyiv, Plescheeva St.,10 (de facto address).
The number of the assessment body № UA.TR.012
Contact phone +38044-360-80-98, +38044-259-46-24

На підставі **Report № 84-C2/25 as 08.08.2025 on assessment of conformity of products to the requirements of module C2 of Technical regulations for appliances running on gaseous fuel (Resolution of the Cabinet of Ministers of Ukraine as 04.07.2018 № 814)**
On the grounds of

Керівник органу з оцінки відповідності **А.П. Олефіренко**
Director of the conformity assessment body
M.P. Stamp

Чинність сертифіката можна перевірити в базі даних органу з оцінки відповідності, що розміщена на:
Validity of the Certificate can be checked on the base of data of the conformity assessment body, which is loaded at:
www.svcoo.kiev.ua